

INSULATE VOID (NOT SHOWN FOR CLARITY)

SHEET-METAL ENCLOSURE WITH REMOVABLE TOP—CROSSBREAK OR SLOPE FOR DRAINAGE

MIN. 4" CLEARANCE FROM PIPE TO TOP OF CURB—MIN. 2" BETWEEN PIPES

SHEET-METAL OR FLEX-TUBE COLLAR

SLOPE PIPES DOWN AND AWAY FROM HOOD

OPTIONAL: REMOVABLE SHEET-METAL COUNTERFLASHING

GASKETED FASTENERS—MIN. TWO PER SIDE

LIQUID APPLIED TOP COAT

LIQUID APPLIED REINFORCED BASE COAT

LIQUID-APPLIED REINFORCED FLASHING

8" MINIMUM FLASHING HEIGHT

SLOPE

SHEET-METAL FLASHING RECEIVER

NOTES

1. THIS DETAIL ILLUSTRATES ANOTHER METHOD OF ELIMINATING PITCH POCKETS AND AN OPTIONAL METHOD OF GROUPING PIPING THAT MUST COME UP ABOVE THE ROOF SURFACE.
2. WHERE THE SHEET-METAL ENCLOSURE OVERLAPS THE BASE FLASHING AT LEAST 3 INCHES, THE REMOVABLE SHEET-METAL COUNTERFLASHING IS NOT REQUIRED.
3. PRIMING OF THE SUBSTRATE MAY BE REQUIRED. FOLLOW SPECIFICATIONS AND MANUFACTURER'S RECOMMENDATIONS.



SHEET TITLE:
**BASE FLASHING AT SHEET-METAL
 ENCLOSURE FULLY REINFORCED
 OVER CONCRETE**

SCALE:
 NTS

DRAWING No.:
DWG NO. LA-CFR-15