

NOTES

- 1. THIS DETAIL ALLOWS THE OPENING TO BE COMPLETED BEFORE THE STACK IS PLACED.
- 2. THE CLEARANCE NECESSARY BETWEEN THE OPTIONAL GYPSUM OR METAL LINER AND THE STACK AND THE NEED FOR INSULATION WILL DEPEND ON THE TEMPERATURE OF THE MATERIAL HANDLED BY THE STACK.
- 3. WHERE THE SHEET-METAL COVER OVERLAPS THE BASE FLASHING AT LEAST 3 INCHES, THE REMOVABLE SHEET-METAL COUNTERFLASHING IS NOT REQUIRED.
- 4. PRIMING OF THE SUBSTRATE MAY BE REQUIRED. FOLLOW SPECIFICATIONS AND MANUFACTURER'S RECOMMENDATIONS.



SHEET TITLE:
BASE FLASHING AT STACK VENT
WITH CURB [HOT OR COLD] FULLY
REINFORCED OVER CONCRETE

SCALE: NTS

DRAWING No.:
DWG NO. LA-CFR-17